


Buffalo County Health Department
407 South Second Street
P.O. Box 517
Alma WI 54610-0517



Telephone: (608) 685-4412
Fax: (608) 685-3342
Email:
dhhs@buffalocounty.com

Buffalo County Health Department
Prevent. Promote. Protect.

September 23, 2014

Township of Buffalo Community Park
ATTN: Steve James
W394 Bluff Siding Rd
Fountain City, WI 54629

RE: Township of Buffalo Community Park

Dear Mr. James:

Enclosed is a copy of the results of the water test performed as part of the TNC water program. The report for this sample indicates there is no bacterial contamination entering your well; therefore it is considered **bacteriologically safe**.

The nitrate level is **ND (None Detected)**, which is below the federal action level of 10 parts per million which means that nitrates are low and therefore the water is safe to drink with respect to nitrates.

The well should be retested annually and any time the well has been repaired, modified, or there is a change in the appearance, taste, odor or flow of the water.

Please contact me by telephone at (608) 685-6331 or by email at calli.heike@buffalocounty.com if have questions or require additional information.

Sincerely,

A handwritten signature in cursive script that reads "Calli Heike".

Calli Heike, REHS
Environmental Health Specialist